

Номер договора \_\_\_\_\_  
Телефон \_\_\_\_\_  
номер теплосчетчика 87293

Гпод.:  $\frac{0,06}{0,06} - \frac{60}{60}$  м3/ч Ду= \_\_\_\_\_ мм  
 Гобр.:  $\frac{0,06}{0,06} - \frac{60}{60}$  м3/ч Ду= \_\_\_\_\_ мм  
 Гп : \_\_\_\_\_ л/Имп

Посуточная ведомость учета параметров теплоснабжения  
с 01.04.2019 по 30.04.2019

Дата	Q Гкал	Масса, тонн			Объем, м3	Температура, °С				Давление		Время, час		Клас с ошиб
		M1	M2	M1-M2 разбор	Vi м3	t1	t2	t1-t2	txв	P1 атм	P2 атм	Нераб. Тн	Работы Тр	
01.04.19	20.150	821.02	843.54	-22.52	0.00	74.0	49.6	24.5	-	7.6	2.5	0.00	24.00	U
02.04.19	19.795	818.76	840.76	-22.00	0.00	74.1	50.0	24.1	-	7.6	2.5	0.00	24.00	
03.04.19	19.486	822.73	844.56	-21.83	0.00	74.0	50.4	23.6	-	7.6	2.5	0.00	24.00	
04.04.19	16.219	649.69	666.93	-17.24	0.00	74.0	49.1	24.9	-	7.6	2.5	0.00	24.00	
05.04.19	14.232	420.81	431.86	-11.05	0.00	73.9	40.2	33.8	-	7.6	2.5	0.00	24.00	
06.04.19	15.004	440.55	452.02	-11.47	0.00	73.9	39.9	34.0	-	7.6	2.5	0.00	24.00	
07.04.19	15.029	439.55	451.03	-11.48	0.00	73.9	39.8	34.1	-	7.6	2.5	0.00	24.00	
08.04.19	14.859	440.66	451.80	-11.14	0.00	73.9	40.2	33.6	-	7.6	2.5	0.01	23.99	
09.04.19	14.455	443.03	453.88	-10.85	0.00	73.4	40.9	32.6	-	7.6	2.5	0.00	24.00	
10.04.19	14.035	443.82	454.11	-10.29	0.00	71.6	40.1	31.6	-	7.6	2.5	0.00	24.00	
11.04.19	14.217	442.73	453.50	-10.77	0.00	71.7	39.7	32.0	-	7.6	2.5	0.00	24.00	
12.04.19	14.244	441.32	452.37	-11.05	0.00	71.7	39.5	32.2	-	7.6	2.5	0.00	24.00	
13.04.19	14.666	452.12	463.30	-11.18	0.00	71.8	39.4	32.4	-	7.6	2.5	0.00	24.00	
14.04.19	15.305	484.69	496.56	-11.87	0.00	71.9	40.3	31.5	-	7.6	2.5	0.00	24.00	
15.04.19	15.381	484.04	495.65	-11.61	0.00	71.8	40.1	31.7	-	7.6	2.5	0.00	24.00	
16.04.19	16.387	679.09	695.28	-16.19	0.00	71.9	47.9	24.0	-	7.6	2.5	0.00	24.00	
17.04.19	13.998	592.44	606.67	-14.23	0.00	71.9	48.3	23.5	-	7.6	2.5	0.02	23.98	
18.04.19	14.222	560.86	574.48	-13.62	0.00	71.8	46.5	25.3	-	7.6	2.5	0.00	24.00	
19.04.19	14.310	518.05	530.43	-12.38	0.00	71.7	44.2	27.5	-	7.6	2.5	0.00	24.00	
20.04.19	14.281	518.16	530.21	-12.05	0.00	71.7	44.3	27.5	-	7.6	2.5	0.00	24.00	
21.04.19	14.136	518.38	530.52	-12.14	0.00	71.7	44.5	27.2	-	7.6	2.5	0.00	24.00	
22.04.19	13.938	518.29	530.41	-12.12	0.00	71.6	44.8	26.8	-	7.6	2.5	0.00	24.00	
23.04.19	13.621	518.28	530.40	-12.12	0.00	71.6	45.4	26.2	-	7.6	2.5	0.00	24.00	
24.04.19	13.581	518.54	530.52	-11.98	0.00	71.5	45.4	26.1	-	7.6	2.5	0.00	24.00	
25.04.19	9.629	399.05	408.58	-9.53	0.00	71.5	47.4	24.0	-	7.6	2.5	0.00	24.00	
26.04.19	7.365	305.82	313.16	-7.34	0.00	71.4	47.4	24.0	-	7.6	2.5	0.87	23.13	
27.04.19	5.821	245.92	251.64	-5.72	0.00	71.3	47.7	23.6	-	7.6	2.5	0.00	24.00	
28.04.19	5.574	270.25	276.61	-6.36	0.00	71.5	51.0	20.5	-	7.6	2.5	0.00	24.00	
29.04.19	5.854	270.09	276.21	-6.12	0.00	71.7	50.1	21.6	-	7.6	2.5	0.00	24.00	
30.04.19	5.689	269.91	276.10	-6.19	0.00	71.7	50.8	21.0	-	7.6	2.5	0.00	24.00	
Итого	405.483	14748.65	15113.09	-364.44	0.00	72.3	44.8	27.5	-	7.6	2.5	0.90	719.10	0.90

### Показания интеграторов КМ-5

Дата Время	Q	M1	M2	Vi	Tr
30.04.19 24:00	2546.927	97983.090	100416.200	0.00	2842.57
01.04.19 00:00	2141.444	83234.437	85303.109	0.00	2123.47
Итого	405.483	14748.653	15113.091	0.00	719.10

Отчетный период	<u>720.00</u>	час.	Период норм. работы	<u>719.10</u>	час.
Период отключения питания (U)	<u>0.902</u>	час.	Период функц. отказа (E)	<u>0.000</u>	час.
Период t1-t2 < min (D)	<u>0.000</u>	час.	Период G < min (g)	<u>0.000</u>	час.
Период G > max (G)	<u>0.000</u>	час.			

Представитель абонента	Представитель теплоснабжающей организации
---------------------------	--