

Номер договора

Телефон _____

Номер теплосчетчика 76787

$$\text{Годр.} : \frac{0,06}{0,06} - \frac{0}{60} \text{ мЗ/ч Дyu} = \frac{\quad}{\quad} \text{ мм}$$

Гп : _____ л/ИМП

с 01.09.2019 по 30.09.2019

Дата	Q Гкал	Масса, тонн			Объем, м3	Температура, °C				Давление		Время, час		Клас ошиб
		M1	M2	M1-M2 разбор	Vi м3	t1	t2	t1-t2	txв	P1 атм	P2 атм	Нераб. Тн	Работы Тр	
01.09.19	2.663	237.96	234.64	3.32	0.00	65.7	54.6	11.1	-	8.0	2.7	0.79	23.21	D
02.09.19	3.109	242.47	239.03	3.44	0.00	70.5	57.8	12.7	-	8.0	2.7	0.00	24.00	
03.09.19	3.052	246.98	243.85	3.13	0.00	70.5	58.2	12.3	-	8.0	2.7	1.77	22.23	D
04.09.19	2.477	193.83	191.41	2.42	0.00	70.3	57.6	12.7	-	8.0	2.7	0.00	24.00	
05.09.19	2.414	196.68	194.22	2.46	0.00	70.4	58.2	12.2	-	8.0	2.7	0.00	24.00	
06.09.19	2.497	193.35	190.93	2.42	0.00	70.4	57.6	12.8	-	8.0	2.7	0.00	24.00	
07.09.19	2.479	198.68	196.21	2.47	0.00	70.4	58.0	12.4	-	8.0	2.7	0.00	24.00	
08.09.19	2.328	186.14	183.86	2.28	0.00	70.3	57.9	12.4	-	8.0	2.7	0.00	24.00	
09.09.19	2.671	203.23	200.72	2.51	0.00	70.4	57.3	13.0	-	8.0	2.7	0.00	24.00	
10.09.19	2.645	210.00	207.44	2.56	0.00	70.4	57.9	12.5	-	8.0	2.7	0.00	24.00	
11.09.19	2.488	204.66	202.17	2.49	0.00	70.3	58.3	12.1	-	8.0	2.7	0.00	24.00	
12.09.19	2.446	200.07	197.59	2.48	0.00	70.3	58.2	12.1	-	8.0	2.7	0.00	24.00	
13.09.19	2.424	200.61	198.10	2.51	36.63	70.3	58.3	12.0	-	8.0	2.7	0.00	24.00	
14.09.19	2.527	210.24	207.61	2.63	0.00	70.4	58.5	11.9	-	8.0	2.7	0.00	24.00	
15.09.19	2.504	212.08	209.42	2.66	0.00	70.6	58.9	11.7	-	8.0	2.7	0.00	24.00	
16.09.19	2.690	224.46	221.70	2.76	0.00	70.7	58.8	11.9	-	8.0	2.7	0.00	24.00	
17.09.19	2.592	223.57	220.81	2.76	0.00	70.7	59.2	11.5	-	8.0	2.7	0.00	24.00	
18.09.19	2.682	232.06	229.21	2.85	0.00	70.7	59.3	11.5	-	8.0	2.7	0.00	24.00	
19.09.19	2.736	233.37	230.46	2.91	0.00	70.8	59.1	11.6	-	8.0	2.7	0.00	24.00	
20.09.19	2.838	238.87	235.92	2.95	0.00	70.7	58.9	11.8	-	8.0	2.7	0.00	24.00	
21.09.19	7.770	392.80	388.65	4.15	0.37	71.2	51.5	19.7	-	8.0	2.7	0.00	24.00	
22.09.19	7.432	373.50	372.54	0.96	0.00	71.2	51.4	19.8	-	8.0	2.7	0.00	24.00	
23.09.19	9.485	411.77	411.50	0.27	0.01	71.3	48.3	22.9	-	8.0	2.7	0.00	24.00	
24.09.19	8.211	382.95	382.98	-0.03	0.00	71.2	49.9	21.4	-	8.0	2.7	0.00	24.00	
25.09.19	7.944	364.53	364.44	0.09	0.00	71.2	49.5	21.7	-	8.0	2.7	0.00	24.00	
26.09.19	7.606	348.11	348.10	0.01	33.83	71.1	49.4	21.8	-	8.0	2.7	0.00	24.00	
27.09.19	7.257	321.23	321.24	-0.01	9.83	71.1	48.6	22.5	-	8.0	2.7	0.00	24.00	
28.09.19	6.792	305.07	305.11	-0.04	2.11	71.0	48.8	22.2	-	8.0	2.7	0.00	24.00	
29.09.19	6.637	292.21	292.16	0.05	0.00	70.9	48.3	22.6	-	8.0	2.7	0.00	24.00	
30.09.19	6.737	297.60	297.60	0.00	0.00	70.9	48.4	22.5	-	8.0	2.7	0.00	24.00	
Итого	128.133	7779.08	7719.62	59.46	82.78	70.5	55.2	15.3	-	8.0	2.7	2.57	717.44	2.57

Показания интеграторов КМ-5

Дата Время	Q	M1	M2	Vi	Tr
30.09.19 24:00	1712.735	65594.950	65417.020	106.81	5232.54
01.09.19 00:00	1584.602	57815.870	57697.400	24.03	4515.11
Итого	128.133	7779.080	7719.620	82.78	717.43

Отчетный период	720.00 час.	Период норм. работы	717.44 час.
-----------------	-------------	---------------------	-------------

Период отключения питания (U) 0.000 час. Период функц. отказа (E) 0.000 час.

Период t1-t2 < min	(D) <u>2.567</u> час.	Период G < min	(g) <u>0.000</u> час.
--------------------	-----------------------	----------------	-----------------------

(G) 0.000 час.

Представитель теплоснабжающей

организации